



EZ PLUMBING PERMIT STANDARD

EZ Plumbing Permit

Obtain permits for installing or altering a plumbing system without submitting plans by meeting the Conditions and Construction Requirements below. A completed ***EZ Plumbing Permit Application Form*** must be submitted with a completed standard Permit Application.

Deviations from this EZ Permit Standard will require submission of plans to the Department with your permit application.

CONDITIONS

- The following types of work are eligible for an EZ Plumbing Permit:
 1. New construction for one- and two-family dwellings.
 2. Alterations and additions for one- and two-family dwellings.
 3. Alterations to 3 and 4 family dwellings.
 4. Alterations in buildings involving no more than 7 new plumbing fixtures with the following exceptions:
 - Projects that involve a change in occupancy.
 - Work involving food preparation equipment.
 5. Replacement in kind of plumbing fixtures, water heaters, and backflow assemblies with no new piping.
 6. Repair or replacement of building traps, building drains, water distribution pipe, soil stacks and any existing plumbing piping.
 7. Installation of new building traps, building drains, and water distribution pipe with a direct connection between the building and the curb stop or building trap.
- All work performed shall be in accordance with the **2018 City of Philadelphia Plumbing Code**.
- Separate PWD permits are required for connections to the City water main or sewer.

PRIOR PERMIT / APPROVALS REQUIRED

- The following permits/approvals must be in place BEFORE an EZ Plumbing Permit can be issued:
 1. An approved PWD site utility plan for all new construction.
 2. A fire suppression permit must be issued where fire and domestic water use the same water service(RFSS).
 3. Exterior plumbing permits for water distribution, building drain, and building trap for all new construction prior to issuing the interior permit.

CONSTRUCTION REQUIREMENTS

Building Sewer / Building Drain Requirements

- Below ground sanitary waste and vent pipe for buildings less than 75' in height servicing one- and two-family dwellings and apartments may be nonmetallic pipe listed in Table 702.2.
- Where the public sewer is a combined system, the sanitary building sewer shall be connected independently to the lateral. Exception: The repair or replacement of existing. (P-703.6)
- Sanitary or combination storm and sanitary building trap shall be a minimum size of 5" and ARC clamps are permitted for replacements. (P-705.3.5)
- Existing sanitary building drains and building sewers must be sized in accordance with Table P- 919.2(c).
- For the underground repair of the building sewer / building drain one MG clamp is permitted. (P-705.3.4)
- For the underground repair of the building sewer / building drain two ARC clamps are permitted when encased in concrete. (P-705.3.4)
- Backwater valves are required on the sanitary building drain or horizontal branch when plumbing fixtures are below the FAI termination of the building trap. (P-714)
- The FAI for the building trap is required to be metallic pipe when within 5' of the water distribution pipe. (P-603.2)

AP# _____ Registered Master Plumber's Signature _____



EZ PLUMBING PERMIT STANDARD

- Unshielded mechanical couplings are not permitted. (P-705.3.3)
- Cellular core PVC and ABS pipe are not permitted to be installed underground. (Table P-702.2, Table P-702.3)
- Compression gasket joints for hub and spigot pipe can be installed for building sewers, building drains, and branches. (705.3.2)
- Pipe-bursting method can be used for the replacement of the building sewer / building drain up to 6" pipe size. (716)

Drain, Waste and Vent (DWV) Requirements

- Above ground sanitary waste and vent pipe for buildings less than 75' in height servicing one- and two-family dwellings and apartments may be nonmetallic pipe listed in Table 702.1.
- Air admittance valves may only be used for single fixture drains other than water closets and only in the alteration of one- and two-family dwelling.(918)
- Open vents that extend through the roof shall be terminated not less than 24" above the roof. (903.1)
- Where a roof is used for assembly, observation deck, sunbathing deck or similar purposes open vent pipes shall terminate 7' above the roof. (903.1)
- Simplex sewage ejector pumps can be used only for one- and two-family dwellings. (P-712.4)
- S traps are permitted only when replacing existing.
- Waterless urinals are permitted in accordance with section 424.
- Philadelphia single-stack waste & vent system cannot be incorporated in any other design method in chapters 7 and 9. (P-919)

Storm Water Requirements

- Storm water sewer pipe for buildings less than 75' in height servicing one- and two-family dwellings and apartments may be non-metallic pipe listed in Table 1102.4.
- Either a building (house) trap 6" minimum size or cleanout is required at the curb line for a dedicated storm sewer. (P-1103.4)
- Where the public sewer is a combined system, the storm building sewer shall be connected independently to the lateral. Exception: The repair or replacement of existing. (P-1109.1)
- Backwater valves are required on the storm building drain or horizontal branch when plumbing fixtures are below the FAI termination of the building trap.(P-1101.9)
- Sizing storm water piping rainfall rates of 4.5" per hour for new construction, 6" per hour for existing buildings without secondary roof drains, and 3.1 per hour for PWD approved green roofs. (1106.1)

Domestic Water Requirements

- Water distribution pipe shall be horizontally separated by not less than 5' when the building sewers and building drains is nonmetallic pipe. A separation of 12" vertical and 12" horizontal from the outer edge of pipe when the building sewers and building drains is metallic pipe.(P-603.2)
- Above and below ground domestic water piping for buildings less than 75' in height servicing one- and two-family dwellings and apartments can be nonmetallic pipe. (P-605.4.1)
- Nonmetallic piping may be used within demised individual residential dwelling located within buildings not more than 150' in height. (P-605.4.1)
- Pressure reducing valve is required when the static water pressure exceeds 80 psi. (P-604.8)
- Backflow containment assembly is required in all buildings except in residential buildings of 4 families or less. (P-608.1.1)
- The developed length of hot or tempered water piping, from the source of hot water to the fixtures that require hot or tempered water shall not exceed 50 feet. (607.2)

AP# _____ Registered Master Plumber's Signature _____



EZ PLUMBING PERMIT STANDARD

- For Group R-2, R-3, and R-4 occupancies that are three stories or less above grade plane, the installation of heated water circulation and temperature maintenance systems shall be in accordance with Section R403.5.1 of the IECC. For other than Group R2, R3, and R4 occupancies that are three stores or less above grade plane, the installation of heated circulation and heat trace systems shall be in accordance with Section C404.6 of the IECC.

Water Heater Requirements

- All water heaters and water heating equipment shall have a minimum of 4' of developed length of copper tubing or similar metallic piping connecting directly to the inlet and the outlet of the unit. (P-503.3)
- Thermal expansion control is required for storage water heaters when there is a backflow assembly, pressure reducing valve, check valve on the incoming water supply of the building or structure. (P-501.9).
- Water heater pans shall be required for storage water heaters where leakage will cause damage. (504.7)
- Water heaters shall be installed in accordance with Chapter 5 of the 2018 PPC, 2018 IFGC, and according to the manufacturer's installation instructions.

Residential Plumbing Mandatory Energy Code Requirements

- Hot water pipe insulation:
 - Hot water pipe insulation value of R-3 or greater has been installed for pipes meeting any of the following conditions:
 - ¾" or greater in nominal diameter
 - Serving more than one dwelling unit
 - Located outside the conditioned space
 - From a water heater to a distribution manifold
 - Located under a floor slab or buried in the ground
 - Recirculation systems other than demand recirculation systems

Commercial Plumbing of All Other Occupancy Mandatory Energy Code Requirements

- Water heaters with storage tanks (excluding solar system circulation loops) include heat traps or heat traps are integral to the equipment.
- Piping insulation thickness installed per 2018 IECC Table C403.11.3
- Drain water heat recovery units:
 - Drain water heat recovery units shall comply with CSA B55.1 or CSA B55.2 as applicable

AP# _____ Registered Master Plumber's Signature _____



CITY OF PHILADELPHIA
 DEPARTMENT OF LICENSES & INSPECTIONS
 Construction Services Division
 Municipal Services Building - Concourse Level
 1401 John F. Kennedy Boulevard
 Philadelphia, Pennsylvania 19102

EZ PLUMBING PERMIT STANDARD

Property Address: _____

The Registered Master Plumber must complete this form and submit it with the completed plumbing permit application before an EZ Plumbing Permit can be processed.

PLUMBING FIXTURES BEING INSTALLED

| TYPE | NUMBER |
|--|--------|
| Area Drains | |
| Backflow Device | |
| Complete Renovation | |
| Floor Drain | |
| Hose Bibbs | |
| Indirect Waste | |
| Sink (Kitchen, Hand, Mop) | |
| Laundry Tray | |
| Lavatory | |
| Roof Drains | |
| Shower/Tub | |
| Sump Pump/Sewage Ejector | |
| Water Closet | |
| Urinal | |
| Other (Include in Description of Work) | |

AP# _____ Registered Master Plumber's Signature _____