



Tire Dealer License Limits & Conditions

This document outlines the Limits and Conditions of the Tire Dealer License.

Tire Dealer License Limits & Conditions

1. The storage of tires and tire by products on sidewalks (right of ways) or streets is prohibited;
2. The storage or display of tires and tire byproducts outdoors is prohibited unless otherwise approved by the Department and compliant with Section 3405 of the Philadelphia Fire Code;

Note: Display piles not exceeding 6 feet in height and limited to a single column or row are permitted, provided that pile is stable and provides for drainage to prevent the accumulation of water.
3. Indoor storage of tires and tire byproducts shall not exceed 6 feet in height unless otherwise approved by the Department through the issuance of a Certificate of Occupancy.
4. Storage of tires shall ensure all the following dimensional requirements are met:
 - a. Storage of tires does not exceed 50 feet in length or width.
 - b. Where tire storage is adjacent or along one wall, storage of tires shall not exceed 25 feet.
5. Storage shall be kept neat and orderly with clear aisles and access to all exits. Minimum clear aisle widths of 36 inches must be maintained for public access and 28 inches for non-public access.
6. Signage prohibiting SMOKING and OPEN BURNING in and around the tire storage areas shall be posted in conspicuous locations.
7. Fire extinguishers shall be maintained in accordance with Section 906 of the Philadelphia Fire Code.
8. Tire buffing operations, when within the same facility, shall be located within a room separated from the remainder of the building by 1-hr fire resistance rated assemblies.
9. Tire manifest must be maintained on-site and be made available to the Department upon request.
10. Current certifications for all fire protection systems shall be maintained. The inspector is required to submit certifications annually through eclipse.phila.gov.