



CITY OF PHILADELPHIA
DEPARTMENT OF LICENSES AND INSPECTIONS

DEFICIENCY NOTICE

SPECIAL HAZARD SUPPRESSION SYSTEMS

I. GENERAL INFORMATION

PROPERTY ADDRESS (as it appears on the property tax records)		LOCATION (Floor, Store, Space Number)
PROPERTY NAME	BUSINESS NAME	
PROPERTY OWNER	OWNER'S PHONE NO.	OWNER'S FAX NO.
OWNER'S E-MAIL ADDRESS	DATE OF INSPECTION	DATE OF NOTICE

II. MAJOR DEFICIENCIES

☐ NONE ☐ CHECKED BELOW ☐ OTHER

<input type="checkbox"/> SYSTEM OUT-OF-SERVICE / IMPAIRED	<input type="checkbox"/> PRE-DISCHARGE ALARM NOT OPERATIONAL
<input type="checkbox"/> LACK OR FAILURE OF GAS OR ELECTRIC SHUT OFF (FUEL SUPPLY)	<input type="checkbox"/> HEAT DETECTION NOT OPERATIONAL
<input type="checkbox"/> UNPROTECTED APPLIANCE	<input type="checkbox"/> PRESSURE GAUGE SHOWS:
<input type="checkbox"/> OBSTRUCTED PROTECTION	<input type="checkbox"/> OVER-CHARGE
<input type="checkbox"/> FIRE SUPPRESSION SYSTEM NOT INSTALLED TO	<input type="checkbox"/> UNDER-CHARGE
MANUFACTURER'S SPECIFICATIONS (MAJOR)	<input type="checkbox"/> AGENT / EXPELLANT GAS LEVELS OUT-OF-RANGE
<input type="checkbox"/> OTHER _____	

III. MINOR DEFICIENCIES IDENTIFIED

☐ NONE ☐ CHECKED BELOW ☐ OTHER

See the City of Philadelphia Fire Alarm Inspection Form for *Complete* Item Description

<input type="checkbox"/> NEW APPLIANCES ADDED - NOT UL-300	<input type="checkbox"/> NOT TIED INTO BUILDING ALARM
<input type="checkbox"/> HYDRO TEST DATE EXPIRED	<input type="checkbox"/> MANUAL RELEASE OBSTRUCTED
<input type="checkbox"/> NO ELECTRIC SHUT-DOWN (NO HEAT SOURCE)	<input type="checkbox"/> EXCESSIVE GREASE, DUST OR RESIDUE
<input type="checkbox"/> FIRE EXTINGUISHER NOT COMPATIBLE WITH HAZARD OR NONEXISTENT	IN CAPTURE DEVICES
<input type="checkbox"/> FIRE SUPPRESSION SYSTEM NOT INSTALLED TO	<input type="checkbox"/> HEAT DETECTION PLACEMENT
MANUFACTURER'S SPECIFICATIONS (MINOR)	
<input type="checkbox"/> OTHER _____	

COMMENTS : _____

PLEASE READ THE FOLLOWING BEFORE COMPLETING THIS FORM

We certify that the above Special Hazard Fire Suppression System, tested in accordance with NFPA and the Philadelphia Fire Code, failed the annual inspection. Systems out of service must be reported immediately to the Philadelphia Fire Department at 215-922-6000.

FIRE SUPPRESSION CONTRACTOR : _____ L&I CONTRACTOR I. D. # _____

INSPECTED BY:

Fire Suppression System Inspector's Name (Must be employed by the contractor/company who has performed the inspection)

Fire Suppression System Inspector's Signature

Date

Fire Suppression System Inspector's License Number

Phone Number

Email Address

COMPLETED NOTICES MUST BE SUBMITTED THROUGH ECLIPSE AT [HTTPS://ECLIPSE.PHILA.GOV/](https://eclipse.phila.gov/).

IF THERE IS AN IMMEDIATE LIFE SAFETY CONCERN (I.E. AN INOPERABLE FIRE ALARM, SUPPRESSION, OR STANDPIPE SYSTEM),
IN ADDITION TO SUBMITTING THE OFFICIAL DEFICIENCY NOTICE PLEASE ALERT OUR FIRE SAFETY UNIT AT
FIRESAFETYUNIT@PHILA.GOV.